

Rigid Vinyl Series – Wall Mounted Pathmarking Door Signs

The **Rigid Vinyl Series – Wall Mounted** Photoluminescent Pathmarking Signs provide visibility and indicate direction of egress in all light conditions. The signs are designed to be installed on the wall beside egress doors with a 3M Foam tape. The photoluminescent signs are visible for many hours after the lights go out, having been charged from sunlight or artificial light.



**UL 1994 AND
ULC 572 Listed**

EXIT TO THE RIGHT	EXIT TO THE LEFT	FINAL EXIT TO THE RIGHT	FINAL EXIT TO THE LEFT	EXIT THROUGH LOBBY LEFT	EXIT THROUGH LOBBY RIGHT
RAE2122-G250R	RBE2122-G250R	RAF2128-G250R	RBF2128-G250R	RBY4219-G250R	RAY4219-G250R
8.4" x 8.89" (213.36mm x 226mm)	8.4" x 8.89" (213.36mm x 226mm)	8.4" x 11.1" (213.36mm x 282mm)	8.4" x 11.1" (213.36mm x 282mm)	16.4" x 7.4" (416.56mm x 188mm)	16.4" x 7.4" (416.56mm x 188mm)

The Ecoglo Rigid Vinyl Series – Wall Mounted Pathmarking Door Signs meets the following Building, Fire & Life Safety Codes:

- IBC/IFC 2009, 2012 (Section 1024 – Luminous Egress Path Markings) and 2015 (Section 1025)
- NFPA 101-2009 and 170-2009
- NYC LL 141 of 2013 (Section BC 1024 Luminous Egress Path Markings)
- NYC LL 26 of 2004 Reference Standard 6-1
- California Building Code Section 1024 Exit Passageways
- Connecticut State Fire Safety Code Section 1026 Floor Proximity Egress Path Markings

Installation Instructions

- Installs easily with 3M foam tape. Some surface preparation is required to ensure a strong bond.
- The foam tape allows for a strong installation on a variety of surfaces. The rigidity of the product spreads any applied load over a greater area of installation adhesion.

Benefits and Technical Details: Ecoglo Rigid Vinyl Series - Wall Mounted Pathmarking Door Signs meets or exceeds the performance criteria specified in the following tests or standards:

Brightness

High visibility in dark or light conditions.

- ASTM E2073-02, Standard Test Method for Photopic Luminance of Photoluminescent (Phosphorescent) Markings.
- ISO 17398:2004 Clause 7.11, Safety Colours and Safety Signs- Classification, Performance and Durability of Safety Signs
- UL 1994 Listed – IMZ1.SA3353
- ULC 572 Listed – IMZ17.SA3353

Washability

Easy Cleaning.

- ASTM D4828-94(2003), Standard Test Methods for Practical Washability of Organic Coatings.

Radioactivity

No radioactivity or toxicity.

- Toxicity: Bombardier SMP 800-C (2000), Toxic Gas Generation Test.

Flammability

Does not burn.

- ASTM E162-02, Standard Test Method for Surface Flammability of Materials Using a Radiant Heat Energy Source.

Contact Ecoglo Inc. for a quick quote or to obtain more information about our emergency lighting products.

KINESIK Engineered Products Incorporated

2213 North Sheridan Way
Mississauga, Ontario L5K 1A3
Canada

Phone: 855.364.7763
Fax: 800.769.4463
www.kinesik.ca